

31604T

7 April 2016

Safari Group of Companies
PO Box 99245
Newmarket
Auckland, New Zealand

Attention: Rob Neil

Dear Rob

Ramada Christchurch, Tuam Street, Christchurch

MSC Consulting Group were engaged as the Structural Consulting Engineers for the Ramada Hotel Building in Tuam Street, Christchurch responsible for the structural design and observation of construction for the project.

The structural design was carried out in accordance with the current New Zealand Design Loadings Code NZS1170:2004 and the current applicable material standards. The design includes the recent increase in Seismic Hazard Factor of 0.3. The building was designed for "normal occupancy" to Importance Level 2 (as defined in NZS1170).

Based on the above the building meets 100% New Building Standard (NBS) and achieves an **NZSEE Seismic Grade of A.**

Yours faithfully

MSC CONSULTING GROUP LTD



Geoff Chilcott

BDOC0005360819.docx

Directors

Geoffrey I. Chilcott B.E. (Hons), N.Z.C.E., M.I.P.E.N.Z., CPEng.

Anil Krishnan B.E. (Hons), M.I.P.E.N.Z., CPEng, INTPE (NZ)

Tom I.C. Donald B.E. (Hons), N.Z.C.E., M.I.P.E.N.Z., CPEng.

Paul J. Culley

Kevin Wyborn BSc (Civil), M.I.C.E., M.I.P.E.N.Z., CPEng.